









1498-ISDS-B-28-07.dwg (DISK: ISDS-B)

LEGEND

- AP. 3 / LOT 153
ASSESSOR'S PLAT/LOT NUMBER
PROPERTY LINE
EXISTING WETLAND EDGE
50' WETLAND PERIMETER
WFA-102
EXISTING WETLAND FLAGS
CB
EXISTING CATCH BASIN
UP-4
EXISTING WELL
EXISTING UTILITY POLE
EXISTING SEPTIC COVER
EXISTING CONTOURS
EXISTING IRON PIN
EXISTING TREE
BENCHMARK
LEDGE TEST
SOIL EVALUATION
GROUNDWATER TEST PIT



ISDS CONFORMANCE NOTE: PRIOR TO RECEIVING A CERTIFICATE OF CONFORMANCE, THE HOMEOWNER SHALL FILE A COPY OF THE APPROVED ISDS PERMIT, OPERATION AND MAINTENANCE AGREEMENT AND MONITORING SCHEDULE OF THE ISDS WITH THE LAND EVIDENCE RECORDS OF THE MUNICIPALITY IN WHICH THE ISDS IS LOCATED.

MAINTENANCE NOTES: 1. THE SEPTIC TANK, ADVANTEX FILTER, PUMP SYSTEM AND BOTTOMLESS SAND FILTER SHALL BE MAINTAINED ANNUALLY. 2. MAINTENANCE SHALL BE PERFORMED IN CONFORMANCE WITH THE PROCEDURES SPECIFIED IN THE COMPONENT'S OPERATION AND MAINTENANCE MANUAL.




EQUIPMENT NOTES: 1. SEPTIC TANK SHALL BE PRECAST WATERTIGHT CONCRETE, 1,500 GALLON W/Baffle OR EQUIVALENT. 2. ALL COMPONENTS SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATIONS.

EXCAVATION NOTES: 1. SOIL, VEGETATION OR DEAD/DECAYING ORGANIC LITTER SHALL BE REMOVED FROM THE AREA PLANNED FOR THE BOTTOMLESS SAND FILTER INSTALLATION.

I.S.D.S. DESIGN DATA table with columns for design category, application rate, area required, BSF dimensions, and total area provided.

ZONING: R-40 table with columns for front, side, rear, and corner setbacks.

FLOOD NOTE: THIS PROPERTY IS LOCATED IN ZONE C-AREAS OF MINIMAL FLOODING, AS DELINEATED ON NATIONAL FLOOD INSURANCE RATE MAP ENTITLED 'TOWN OF JAMESTOWN RHODE ISLAND NEWPORT COUNTY COMMUNITY-PANEL NUMBER 445399 0003 B MAP REVISED: FEBRUARY 19, 1998.'



REVISION table with columns for NO., DATE, and REVISION.

JOHN P. CATO CIVIL ENGINEERS 141 JAMES P. MURPHY HIGHWAY WEST WARWICK, RHODE ISLAND 02883 401-615-8600

CLAUDIA J. VILLAMIZAR LAND PLANNER 141 JAMES P. MURPHY HIGHWAY WEST WARWICK, RHODE ISLAND 02883 401-615-8600

PROJECT NO: 7931499 DATE: AUGUST 2007 SCALE: 1" = 20'

DESIGNED BY: J.C.H. DRAWN BY: C.M.W. CHECKED BY: J.P.C.

PLAN OF PROPOSED INDIVIDUAL SEWAGE DISPOSAL SYSTEM ASSESSOR'S PLAT 3/ LOT 153 DORY STREET

DRAWING NUMBER 1 SHEET 1 OF 1