



CRITTER CROSSING #3
AT GRADE CROSSING

BLAST LEDGE TO 1:6
SLOPE AS NEEDED

CRITTER CROSSING #3
AT GRADE CROSSING

MATCHLINE PANEL 2

MATCHLINE PANEL 1

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF WATER RESOURCES
FRESHWATER WETLANDS PROGRAM
APPROVED WITH CONDITIONS
AS SPECIFIED IN THE LETTER OF APPROVAL
DATE JUN - 4 2008 FILE # 07-0480
NO CHANGES ALLOWED WITHOUT PRIOR APPROVAL
APPROVED PLANS MUST BE AT CONSTRUCTION SITE.
Ernest Jencel

*Revised per DEM:
The slope must be stabilized with an erosion control mat, and then loamed and seeded. No rip-rap shall be used to stabilize the slope.*

APR 21 2008

NOTE:

REFER TO GRADING PLANS IN THE SET ENTITLED "SITE PLANS FOR FM GLOBAL, CENTRAL AVENUE, JOHNSTON, RI" PREPARED BY VHB, INC, AS REVISED BY Δ2 ON 02/27/08.

CRITTER CROSSING #2
2-48" HDPE
INV. IN=121.0
INV. OUT=113.0

*Revised per DEM:
To be installed consistent with the "Critter Crossing End Section View" Detail provided on Detail Sheet 4 of the originally approved site plans of March 3, 2008.*

EROSION CONTROL MAT (SEE DETAIL)

CRITTER CROSSING #1
2-48" HDPE
INV. IN=117.0
INV. OUT=115.0

0 20 40 Feet

Vanasse Hangen Brustlin, Inc.

Figure 1 April 18, 2008

New Critter Crossings
FM Global
Central Avenue
Johnston, RI