



RHODE ISLAND

DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

235 Promenade Street, Providence, RI 02908-5767

TDD 401-222-4462

May 9, 2017

West River Commerce Center Annex LLC
C/o E.A. Amaral, Operating Manager
5 Fenner Grant Lane
Cumberland, RI 02864-1632

Insignificant Alteration – Permit

RE: Wetland Application No. 17-0035 in reference to the property and proposed project located:

Approximately 315 feet west-northwest of West River Street (148 West River Street); approximately 615 feet west-southwest of Corliss and West River Streets; and approximately 90 feet west of West River Street; approximately 330 feet north-northwest of the intersection of Corliss and West River Streets; Assessor's Plat 100, Lots 15 & 49, and Assessor's Plat 74, Lot 368, Providence, RI.

Dear Mr. Amaral:

Kindly be advised that the Department of Environmental Management's ("DEM") Freshwater Wetlands Program ("Program") has completed its review of your **Request for Preliminary Determination** application and has evaluated the proposed construction of a 6,985 square foot addition to an existing building and the construction of a floodplain compensation/riverbank wetland enhancement area, as illustrated and detailed on site plans submitted with your application. These site plans were received by the DEM on April 19, 2017.

Our observations of the subject property, review of the site plans and evaluation of the proposed project reveals that alterations of freshwater wetlands are proposed. However, pursuant to Rule 9.00 of the Rules and Regulations Governing the Administration and Enforcement of the Fresh Water Wetlands Act (Rules), this project may be permitted as an **insignificant alteration** to freshwater wetlands under the following terms and conditions:

Terms and Conditions for Application No. 17-0035:

1. This letter is the DEM's permit for this project under the R.I. Fresh Water Wetlands Act, Rhode Island General Laws (RIGL) Section 2-1-18 et seq.
2. This permit is specifically limited to the project, site alterations and limits of disturbance as detailed on the site plans submitted with your application and received by the DEM on April 19, 2017. A copy of the site plans stamped approved by the DEM is enclosed. Changes or revisions to the project which would alter freshwater wetlands are not authorized without a permit from the DEM.
3. Where the terms and conditions of the permit conflict with the approved site plans, these terms and conditions shall be deemed to supersede the site plans.
4. You must notify this Program in writing immediately prior to the commencement of site alterations and upon completion of the project.

5. A copy of the stamped approved site plans and a copy of this permit must be kept at the site at all times during site preparation, construction, and final stabilization. Copies of this permit and the stamped approved plans must be made available for review by any DEM representative upon request.
6. Within ten (10) days of the receipt of this permit, you must record this permit in the land evidence records of the City of Providence and supply this Program with written documentation obtained from the City showing this permit was recorded.
7. The effective date of this permit is the date this letter was issued. This permit expires four (4) years from the date of issue.
8. Any material utilized in this project must be clean and free of matter which could pollute any freshwater wetland.
9. Prior to commencement of site alterations, you shall erect or post a sign resistant to the weather and at least twelve (12) inches wide and eighteen (18) inches long, which boldly identifies the initials "DEM" and the application number of this permit. This sign must be maintained at the site in a conspicuous location until such time that the project is complete.
10. Temporary erosion and sediment controls detailed or described on the approved site plans shall be properly installed at the site prior to or commensurate with site alterations. Such controls shall be properly maintained, replaced, supplemented, or modified as necessary throughout the life of this project to minimize soil erosion and to prevent sediment from being deposited in any wetlands not subject to disturbance under this permit.
11. You are obligated to install, utilize and follow all best management practices detailed or described on the approved site plans in the construction of the project to minimize or prevent adverse impacts to any adjacent freshwater wetlands and the functions and values provided by such wetlands.
12. Excavation to compensate for loss in flood storage as provided on the approved site plans is mandatory and must be completed prior to any filling or construction alterations within flood plain or areas subject to flooding on the subject property. Written certification must be provided to this Program by a registered land surveyor that such excavation and grading has been accomplished as permitted. Such certification shall be submitted within twenty (20) days of completion of the required excavation and grading.
13. All plantings of shrubs, trees or other forms of vegetation as shown or detailed on the approved plans, or detailed in this permit, must be installed as soon as possible after completion of final grading; weather and season permitting.
14. All trees that do not survive a growing season shall be replaced in kind.
15. All tree plantings depicted within the Floodplain Compensation and Enhancement Area, except for necessary replacement, must be allowed to develop naturally without being subjected to mowing or manicuring.

Kindly be advised that this permit is not equivalent to a verification of the type or extent of freshwater wetlands on site. Should you wish to have the types and extent of freshwater wetlands verified, you may submit the appropriate application in accordance with Rule 8.03.

Application No. 17-0035

Page 3 of 3

You are required to comply with the terms and conditions of this permit and to carry out this project in compliance with the Rules at all times. Failure to do so may result in an enforcement action by this Department.

Pursuant to the provisions in Rule 7.09 and Rule 11.04, as applicable, any properly recorded and valid permit is automatically transferred to the new owner upon sale of the property.

In permitting the proposed alterations, the DEM assumes no responsibility for damages resulting from faulty design or construction.

This permit does not remove your obligation to obtain any local, state, or federal approvals or permits required by ordinance or law and does not relieve you from any duties owed to adjacent landowners with specific reference to any changes in drainage.

Please contact Daniel Kowal of this office (telephone: 401-222-4700, ext. 7416) should you have any questions regarding this letter.

Sincerely,



Martin D. Wencek, Permitting Supervisor
Freshwater Wetlands Program
Office of Water Resources

MDW/DMK/dmk

Enclosure: Approved site plans

xc: David Rodio, Providence Building Official
Dave Taglianetti, VHB